

I DT LD MF Frenstat

repair parts list for 1LG4 (normal version) IP 55 shaft height 225

spare part	pos.	description	order number	all order data in PMD*
bearing endshield DE B3	1.40		CZF:32417321614400	
flange DE B5	1.40		CZF:32417311681800	
spring lock washer	1.58		CZF:30000981100040	
rolling-contact bearing DE	1.60	6213-ZC3	CZF:30000341351630	
shaft sealing ring DE	1.43	V-Ring	CZF:30000981000101	
terminal box, complete	5.00	gk 431	*	
terminal board, complete	-		*	
terminal box, top section	5.44		CZF:32827412239699	
seal for term.box, top section	5.03		CZF:32997436524302	
terminal box cover	5.84		CZF:32837212239800	
gasket for term.box cover	5.83		CZF:32997436524402	
bearing endshield NDE	6.20		CZF:32417321614400	
shaft sealing ring NDE	6.23	V-Ring	CZF:30000981000101	
circlips NDE	3.02		CZF:30000371500650	
circlips NDE	6.02		CZF:30000371601200	
rolling-contact bearing NDE	6.10	6213-ZC3	CZF:30000341351630	
fan plastic 2-pole	7.04	d = 200	CZF:33237111719203	
fan plastic 4-6-8-pole	7.04	d = 280	CZF:33237111719206	
fan cowl	7.40		CZF:33337211858901	
canopy complete	-		CZF:39007411842002	
housing feet, right	4.07		CZF:32117436551500	
housing feet, left	4.07		CZF:32117436551600	

*PMD-Link

[https://c2pweb.automation.siemens.com/ad_pmd_pwi\(bD1kZSZjPTA5MA==\)/cockpit.xml](https://c2pweb.automation.siemens.com/ad_pmd_pwi(bD1kZSZjPTA5MA==)/cockpit.xml)

* Order only according order no. and serial no.of the motor

Notice : These data are not valid for motors with increased power. (with "8" on the 7th position in order number)

The following information should be specified in all orders for spare parts:

- Part designation and number
- order no. and serial no.of the motor

pos.1.40 (6.20) has to be ordered with shaft sealing ring pos.1.43 (6.23)

contact for order processing:

I CS LS LD ENG MOF3 Mrs.Jana Raskova

Tel. +420 556 207 679

Fax +420 556 207 684

jana.raskova@siemens.com

contact for spare parts quotation:

I CS LS LD ENG MOF

adrepair.motors@siemens.com

Tel. +420 556 207 777