

Producer: Siemens Standard Motors Ltd.								
Address : No. 110, West Street Qingshan Town Yizheng City Jiangsu Province 211417, P.R.China								
TYPE TEST CERTIFICATE OF INDUCTION MOTOR								
TEST No...Probe Nr. :								
TYPE... : 1LG0106-4AA		SERIAL-No: 29989		spec.: 3				
2.2 kW	380 V	Y	5.16 A	1410 /min	50 Hz			
S1	IP55	Isol. F	40 °C	IM B3	31 kg			
WINDING RESISTANCE - cold					$R_{f20} = 4.205945 \ \Omega$			
TERMINALS:		U-V	U-W	V-W	$R_{isol} > 0.5 \ G\Omega$			
$\vartheta = 11 \ ^\circ\text{C}$	$R (\ \Omega) :$	2.70500	2.70500	2.70500				
$M_N = 14.9 \ \text{Nm}$	LOAD TEST						1. MEASURING	
	1.	2.	3.	4.	5.	6.		
$P_{in} \ (W)$	3202	2677					2. CORRECTED for Pn	
$P \ (W)$	2614	2200	2200			2200		
$U \ (V)$	380					380		
$I \ (A)$	5.8	4.9	4.9			5.16		
$f \ (Hz)$	50	50	50			50		
SPEED $(1/min)$	1412	1426	1426			1410	3. CORRECTED FOR T_{REF} according EN 60034-2	
Torque (Nm)	17.7							
$\eta \ (\%)$	81.65	82.17	81.8			79.7		
$\cos \varphi \ (-)$	0.833	0.828				0.81		
$M_{ST} / M_N \ \blacklozenge \ M_A / M_N \ (-)$	2.8	2.8				2.3		
$I_{ST} / I_N \ \blacklozenge \ I_A / I_N \ (-)$	6.4	6.4				7.0	4. CORRECTED FOR T_{REF} according CEMEP	
$M_{MAX} / M_N \ \blacklozenge \ M_K / M_N \ (-)$	2.75	2.75				2.3		
SLIP ... $(\%)$	5.87	4.94				6.00		
WINDING - $\Delta \vartheta \ (K)$	69.5 (30 s)	53.8 (30 s)	EN 60034-2 $T_{ref} = 95^\circ\text{C}$			80		
$\vartheta_a \ (^\circ\text{C})$	13	13						
FRAME - $\Delta \vartheta \ (K)$	25	19.4					5. MEASURING at 75% Pn	
TIME ... (min)	180							
BEARING_D - $\Delta \vartheta \ (K)$	35	27.1					6. GUARANTED	
RESISTANCE - warm	3.49100	3.31894	... U-V	$R_{isol} = 0.2 \ G\Omega$				
$(\ \Omega)$	3.49100	3.31894	... U-W					
	3.49100	3.31894	... V-W					
NO-LOAD TEST				LOCKED ROTOR TEST				
VOLTAGE	CURRENT	POWER INPUT	POWER FACTOR	VOLTAGE	CURRENT	TORQUE	POWER INPUT	POWER FACTOR
$U_o \ (V)$	$I_o \ (A)$	$P_o \ (W)$	$\cos \varphi_o \ (-)$	$U_A \ (V)$	$I_A \ (A)$	$M_A \ (N.m.)$	$P_A \ (W)$	$\cos \varphi_A \ (-)$
380	3.09648	278	0.136	380	32.8	41.4	15573	0.721
COIL TEST		HIGH-SPEED TEST		HIGH POTENCIAL TEST				
130% U_N - 3 min.		120% n_{MAX} - 2 min.		2500 V - 1 min.				
TESTS CONFORM to the ... EN 60034								
NOTE							order:	
A&D SD MF QM		DATE... 24/11/2008		PAGE... 1 / 6		SIGNATURE LAZ		